

# Loss Prevention Inspection Checklist



## Crane Checklist

All cranes, owned or leased, shall be checked upon arrival at the project by the subcontractor (user) prior to use. The original of this check list is to be provided to the General Contractor.

Name of Subcontractor (user): \_\_\_\_\_

Name of Lessor (if different): \_\_\_\_\_

Make of Crane: \_\_\_\_\_ Serial #: \_\_\_\_\_

Maximum lifting capacity: \_\_\_\_\_ (tons) Max. boom length \_\_\_\_\_ (ft)

Yes	No	NA
-----	----	----

Valid certificate or other proof of annual inspection

Boom angle indicator operable

Load indicating device if capacity exceeds 3 tons

### TWO-BLOCK DEVICE

Lattice: Anti-two-block device or two-block warning device

Hydraulic: Anti-two-block device or anti-two-block damage prevention feature

Load chart in operator's cab

Operating instructions in cab

Fire extinguisher on crane

Operator is competent, qualified and tested on this crane.

Suspended personnel platform will be used

Inspected By: \_\_\_\_\_

Employer: \_\_\_\_\_ Date: \_\_\_\_\_

The illustrations, instructions and principles contained in the material are general in scope and, to the best of our knowledge, current at the time of publication. No attempt has been made to interpret any referenced codes, standards or regulations.

Please refer to the appropriate code-, standard-, or regulation-making authority for interpretation or clarification.

Provided that you always reproduce our copyright notice and any other notice of rights, disclaimers, and limitations, and provided that no copy in whole or in part is transferred, sold, lent, or leased to any third party, you may make and distribute copies of this publication for your internal use.